


LAPORAN
REKAP HASIL SAMPEL AIR LIMBAH
PELABUHAN PERIKANAN NUSANTARA PEMANGKAT
BULAN JANUARI
TAHUN 2025

NO	TANGGAL	LOKASI	PEMERIKSAAN	HASIL
1	20 Januari 2025	Kantor Utama	Ph air Suhu	7,23 28,2°C

DOKUMENTASI
REKAP HASIL SAMPEL AIR LIMBAH
PELABUHAN PERIKANAN NUSANTARA PEMANGKAT
BULAN JANUARI
TAHUN 2025



Mengetahui,

Ketua Tim kerja TKPU


(Dicky Septiandi, S.S.T.Pi)

Petugas


(Abdu Rahman)

Report No. 18503/BOEBAR
Date: December 30, 2024

Issuing Office:
Jl. Arteri Supadio KM.12,5. Sungai Raya - Kubu Raya, Indonesia
Phone/Facs: +62 561 - 733334/0561 - 736319
Email: pontianak@sucofindo.co.id

REPORT OF ANALYSIS

CLIENT : Pelabuhan Perikanan Nusantara Pemangkat
Ditjen Perikanan
TYPE OF SAMPLE : Waste Water
DATE RECEIVED : December 03, 2024
DATE OF ANALYSIS : December 03, 2024 to December 30, 2024
TESTED FOR : Physical, Chemical and Microbiological Test
Regulation of the Minister of Environment and Forestry of the Republic
of Indonesia Number P.68/Menlhk/Setjen/Kum.1/8/2016
DESCRIPTION OF SAMPLE : Packing : Unsealed plastic jerry can
SAMPLE IDENTIFICATION : Air Limbah
YOUR REFERENCE : 4172/LAB.AKL/PTK-XII/2024

Result :

Parameter	Unit	Result	Methods
pH at Lab**)	-	7.0	SNI 6989.11:2019
BOD ₅ days 20°C	mg/L	7.94	5210 B
COD by K ₂ Cr ₂ O ₇ **)	mg/L	26.5	SNI 6989.73:2019
TSS (Total Suspended Solid)**)	mg/L	22	SNI 6989.3:2019
Oil and Grease	mg/L	2.5	5520 B
Ammonia**)	mg/L	0.14	SNI 06-6989.30:2005
Total Coliform	Total / 100 mL	1042	9222 B

Sampling is carried out by customer, so the test results are only used internally

*) SNI : Standar Nasional Indonesia; Standard Methods Ed 24, 2023, AWWA, APHA, WPCF

***) Included the scope of accreditation KAN

< = Less than the detection limit indicated

This test result (s) related to the sample (s) submitted only and the report / certificate can not be reproduced in any way, except in full context and with the prior approval in writing from Sucofindo Laboratory

This Certificate/report is issued under our General Terms and Conditions, copy of which is available upon request or may be accessed at www.sucofindo.co.id

 **Sucofindo Laboratory**

SUCOFINDO
Ari Hambali

60010224004088
Ah-Ok/Lab.AKL.24



5103163

