

LAPORAN
REKAP HASIL AIR LIMBAH PELABUHAN
BULAN NOVEMBER
TAHUN 2024

NO	TANGGAL	LOKASI	PEMERIKSAAN	HASIL
1	21 November 2024	Jatty Kayu	Salinitas Ph air Suhu	0,90 6,3 29,0 °C
		Jetty Beton	Salinitas Ph air Suhu	0,69 6,1 28,5 °C
		Dermaga Kayu	Salinitas Ph air Suhu	0,90 6,80 29,4 °C

Penanggungjawab sementara

Ketua Tim Kerja Kesyahbandaran



(Am Yumansyah S.ST.Pi)

Petugas

(Arie Fakhrial)

Dokumentasi
Pengukuran Air Limbah Pelabuhan Bulan November 2024



Report No. 09600/BOEBAR
Date: August 07, 2024

Issuing Office:
Jl. Arteri Supadio KM.12,5. Sungai Raya - Kubu Raya, Indonesia
Phone/Facs: +62 561 - 733334/0561 - 736319
Email: pontianak@sucofindo.co.id

REPORT OF ANALYSIS

CLIENT : Pelabuhan Perikanan Nusantara Pemangkat
TYPE OF SAMPLE : Waste Water
DATE RECEIVED : July 26, 2024
DATE OF ANALYSIS : July 26, 2024 to August 07, 2024
TESTED FOR : Physical, Chemical and Microbiological Test
Regulation of the Minister of Environment and Forestry of the Republic of Indonesia Number P.68/Menlhk/Setjen/Kum.1/8/2016
DESCRIPTION OF SAMPLE : Packing : Unsealed plastic jerry can
SAMPLE IDENTIFICATION : Air Limbah - IPAL
YOUR REFERENCE : 2396/LAB.AKL/PTK-VII/2024

Result :

Parameter	Unit	Result	Methods
pH at Lab	-	6.3	SNI 6989.11:2019
BOD ₅ days 20°C	mg/L	44.7	5210 B
COD by K ₂ Cr ₂ O ₇	mg/L	149	SNI 6989.73:2019
TSS (Total Suspended Solid)	mg/L	6	SNI 6989.3:2019
Oil and Grease	mg/L	2.3	5520 B
Ammonia	mg/L	0.85	SNI 06-6989.30:2005
Total Coliform	Total / 100 mL	1096	9222 B

Sampling is carried out by customer, so the test results are only used internally

*) SNI : Standar Nasional Indonesia; Standard Methods Ed 23, 2017, AWWA, APHA, WPCF

< = Less than the detection limit indicated

This test result (s) related to the sample (s) submitted only and the report / certificate can not be reproduced in any way, except in full context and with the prior approval in writing from Sucofindo Laboratory

This Certificate/report is issued under our General Terms and Conditions, copy of which is available upon request or may be accessed at www.sucofindo.co.id

Sucofindo Laboratory

SUCOFINDO
Ari Hambali

60010224002335
Ah-Ok/Lab.AKL.24



4940247



SCI-2023A