

KEGIATAN PENGAMBILAN SAMPEL AIR LIMBAH OUTLET DI PPN KEJAWANAN CIREBON BULAN DESEMBER 2024

A. IDENTITAS

Nama Perusahaan : PELABUHAN PERIKANAN NUSANTARA (PPN) KEJAWANAN
Alamat Pemrakarsa : Jalan Pelabuhan Perikanan No. 1 Cirebon
Jenis Perusahaan : Instansi Pemerintah
Status pemodalan : APBN
Bidang usaha : Pelabuhan Perikanan



Gambar.1 Papan Nama

B. LAMPIRAN DOKUMENTASI

Hasil Pengambilan Sampel :

SAMPEL YANG DIAMBIL	VOLUME	TITIK LOKASI SAMPEL
Pengambilan sampel air limbah Outlet		IPAL


DATA DUKUNG



Pengambilan sampel air limbah Outlet		IPAL
DATA DUKUNG  10 Des 2024 10.48.57 Jalan Pelabuhan Perikanan Pegambiran Kecamatan Lemahwungkuk Kota Cirebon Jawa Barat  10 Des 2024 10.46.24 Jalan Pelabuhan Perikanan Pegambiran Kecamatan Lemahwungkuk Kota Cirebon Jawa Barat		

Cirebon, Desember 2024

Petugas



Ivan Somantri

Mengetahui
Ketua Tim Kerja TKPU



Sri Handayani,S.St.Pi

Issuing Office:
Jl. Dr. Sudarsono No. 46 Cirebon 45134, Indonesia
Phone/Facs: +62 231 242284/205018
Email: cirebon@sucofindo.co.id

CERTIFICATE OF SAMPLING AND ANALYSIS

PRINCIPAL : PELABUHAN PERIKANAN NUSANTARA KEJAWANAN
Jl. Pelabuhan Perikanan No. 1 Kelurahan Pengambiran,
Kec. Lemah Wungkuk, Kota Cirebon

TYPE OF SAMPLE : WASTE WATER

DATE OF SAMPLE RECEIVED : December 10, 2024

DATE OF ANALYSIS : December 10 to 24, 2024

TESTED FOR : Physical and Chemical test
(Environmental Minister Regulation No.5/2014 Appendix XIV)

DESCRIPTION OF SAMPLE : Sample was drawn by Sucofindo Laboratory
Dated of Sampling : December 10, 2024
Plan and Sampling Method : SNI 6989.59 : 2008
Weather : Clear

SAMPLE IDENTIFICATION : Air Limbah Outlet

YOUR REFERENCE : -

Parameter	Unit	Test Result	Environmental Quality Standard	Methods*) Part Number
pH (on site)	-	7.83	6-9	4500-H ⁺ -B
Total Suspended Solid	mg/L	66	100	2540 D
Sulfida (H ₂ S)	mg/L	0.03	1	PO/CRB-LP/27 (Spektrofotometer)
Ammonia	mg/L	5.08	5	4500-NH ₃ -F
Chlorine Free (Cl ₂) (on site)	mg/L	0.19	1	PO/CRB-LP/05
BOD ₅ •	mg/L	28.8	100	5210 B
COD	mg/L	82.4	200	PO/CRB-LP/21 (Spektrofotometer)
Oil & Grease	mg/L	12.8	15	5520 B

*) Standard methods, 23th Edition 2017, APHA-AWWA-WEF
•) Excluded the scope of accreditation KAN
< = Less than the detection limit indicated

This Certificate/report is issued under our General Terms and Conditions, copy of which is available upon request or may be accessed at www.sucofindo.co.id

40010124001420

Inspection And Testing

SUCOFINDO
Neneng Mamah Ruhimah



5083986



SCI-2023A