

LAPORAN KEGIATAN
PENGUJIAN KUALITAS LINGKUNGAN PPN KARANGANTU
JUNI 2025

NAMA PETUGAS : AANG RAMADHON
 KEGIATAN : PENGUJIAN KUALITAS UDARA
 METODE : ALAT SEDERHANA
 WAKTU PELAKSANAAN : 26 JUNI 2025

HASIL:

1. RUANG OPERASIONAL

No.	Parameter	Hasil	Standar Baku	Keterangan
1	CO2	406 ppm	350 - 700 PPM (WHO, 2005)	Sesuai
2	PM2.5	87 $\mu\text{g}/\text{m}^3$	<150,4 $\mu\text{g}/\text{m}^3$ (Permen LHK No P.14/2020)	Sesuai
3	TVOC	0.021 Mg/m^3	<0,34 mg/m^3 (PMK 1077/2011)	Sesuai
4	HCHO	0.005 Mg/m^3	<0.12 mg/m^3 (PMK 1077/2011)	Sesuai
5	KELEMBAPAN	52%	40-60 % Rh (PMK 1077/2011)	Sesuai
6	SUHU	28.5	18 - 30 (PMK 1077/2011)	Sesuai

dokumentasi:



Mengetahui,
 Kepala Tim Kerja TKPU
 PPN Karangantu

Murlian Aprianto

Petugas:

1. Aang R